Supply of Inverter (1 no.)

Reference Order No.: iSenS/MLP-2030/2024/DP-10

- 1. The order should not be preferably split. The comprehensive quote considering fabrication/fitment of all components, for at CSIO will be considered.
- 2. The required quantity is mentioned against each component in annexure 1. The components should be sealed /packed as per the original factory packing. If found damaged, will be returned.
- 3. The price should be including ex-CSIO delivery.
- 4. The valid coc/inspection report should be shared wherever applicable.
- 5. The supplier should share the authorization letter from the OEM, wherever applicable.
- 5. Payment and other things as per CSIO norms.
- 6. Pl mail at spo@csio.res.in and kumarmukesh@csio.res.in
- 7. Quote time by 11:00AM on 11.03.2024.
- 8. The details of the user will not be shared.
- 9. Material to be supplied on or before March 15, 2024

Specifications

- 1. Type of Product: Grid Tie Inverter
- 2. Transformer less GTI with efficiency of more than 97%
- 3. Inbuilt MPPT charge controllers to extract upto 30% more power from panels
- 4. IP65 enclosure: Dust and waterproof
- 5. Communication: for remote monitoring
- 6. VA Rating: 3 KW
- 7. Input Voltage Range: 80-500 V
- 8. Panel Capacity: 3500 W